

MCCB Panel 1 CIRCUIT DETAILS

SCHEDULE DETAILS					
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ
Location of Board:	Compton House		Supplied From:	N/A	
Overcurrent Device:	N/A		Rating:	N/A	
RCD Device:	N/A		RCD Rating:	N/A	
				Nominal Voltage:	N/A
				RCD No of Poles:	N/A

CIRCUIT DETAILS													
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	Max disconnect time permitted by BS7671 s	BS(EN)	Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω
1L1	Fire Alarm Panel												
1 L2	Sub Main (DB 6)												
1 L3	Sub Main (DB 1) (Supply to D.B. 1)												
2L1	Sub Main (DB 5)												
2 L2	Sub Main (DB 2)												
2 L3	Spare												
3L1	Sub Main (DB 3)												
3 L2	Spare												
3 L3	Spare												
4 TP	Main Ventilation Panel												
5 TP	Way Not Available												
6 TP	Boiler Panel												
7 TP	Spare												
8 TP	Spare												
9 TP	Spare												
10 TP													

ADDITIONAL COMMENTS

SCHEDULE DETAILS					
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ
Location of Board:	Compton House	Supplied From:	MCCB Panel 1 - 1 L3	Nominal Voltage:	230 V
Overcurrent Device:		Rating:	A	RCD No of Poles:	
RCD Device:		RCD Rating:	mA		

CIRCUIT DETAILS														
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	BS(EN)		Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω	
1 L3	Lights - G/F Link Corridor/Internet Room/Telephone Room	A	100	5	1.0	1.0	0.4	3871	2	10	6	N/A	3.29	
2 L3	Lights - Ground Floor Antrium Office	A	100	12	1.5	1.0	0.4	3871	4	10	4	N/A	---	
3 L3	Lights - First Floor Atrium	A	100	10	1.5	1.0	0.4	3871	4	10	4	N/A	---	
4 L3	Lights - G/F Atrium	A	100	8	1.5	1.0	0.4	3871	2	15	7.5	N/A	2.19	
	Way Not Available	---	---	---	---	---	---	---	---	---	---	---	---	
5 L3	Lights - External	A	C	2	1.5	1.0	0.4	3871	4	15	7.5	N/A	---	
	Way Not Available	---	---	---	---	---	---	---	---	---	---	---	---	
6 L3	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
7 L3	Sockets - G/F Atrium Office	A	C	4	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
8 L3	Sockets - Telephone Equipment rm	A	C	4	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
9 L3	Sockets - Telephone Equipment rm	A	C	2	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
10 L3	Sockets - Ground Floor Atrium Office	A	C	12	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
11 L3	External Lighting Control	A	100	---	---	---	---	3871	4	---	4	N/A	---	

ADDITIONAL COMMENTS													

SCHEDULE DETAILS					
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ
Location of Board:	Main Building	Supplied From:	Origin	Nominal Voltage:	230 V
Overcurrent Device:		Rating:	A	RCD No of Poles:	
RCD Device:		RCD Rating:	mA		

CIRCUIT DETAILS														
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	BS(EN)		Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω	
1 L1	Lights - Corridor/Atrium Kitchen	A	100	9	1.5	1.0	0.4	3871	4	10	4	N/A	---	
2 L1	Lights - Poison /Plant/Comms Rms/Ground Floor Offices/Lobby	A	100	10	1.5	1.0	0.4	3871	4	10	4	N/A	---	
3 L1	Sockets - Corridor/ Plant Rm/Offices/Poison Rm Water Heater	A	C	6	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
4 L1	Socket - Boiler Room	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
5 L1	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
6 L1	Water heater (Not Located)	---	---	---	---	---	---	---	---	---	---	---	---	
7 L1	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
8 L1	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
9 L1	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
10 L1	Smoke Detector Supply (Not Found)	---	---	---	---	---	---	---	---	---	---	---	---	
11 L1	Sockets - Office Dado/External twin Spot EM Light	A	B	9	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
12 L1	Socket - Strong Rm/Heater Spur/Light Supply	A	C	4	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
13 L1	Sockets - Comms Room	A	C	12	2.5	1.5	0.4	60898	B	32	10	N/A	1.44	
14 L1	Spare	---	---	---	---	---	---	---	---	---	---	---	---	

ADDITIONAL COMMENTS													

SCHEDULE DETAILS			
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX	Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ
Location of Board:	First Floor kitchen	Supplied From:	Origin
Overcurrent Device:		Rating:	A
RCD Device:		RCD Rating:	mA
		Nominal Voltage:	230 V
		RCD No of Poles:	

CIRCUIT DETAILS														
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	BS(EN)		Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω	
1 L1	Lights - Council Chamber Chandiliers	A	100	2	1.5	1.0	0.4	3871	4	10	4	N/A	---	
2 L1	Lights - Council Chambers Wall + Chandilier	A	100	5	1.5	1.0	0.4	3871	4	10	4	N/A	---	
3 L1	Lights - Kitchen/Toilets/Chambers Corridor + 2 Chandiliers	A	100	14	1.5	1.0	0.4	3871	4	10	4	N/A	---	
4 L1	Sockets - Kitchen/ Corridor	A	C	3	2.5	1.5	0.4	3871	4	20	4	N/A	---	
5 L1	Sockets - Chamber/Registrars/Corridors	A	C	10	2.5	1.5	0.4	3871	4	32	6	N/A	---	
	Way Not Available	---	---	---	---	---	---	---	---	---	---	---	---	
6 L1	Sockets - Spur in Chambers and Registrars	A	C	6	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
	Way Not Available	---	---	---	---	---	---	---	---	---	---	---	---	
7 L1	Kitchen Water Heater	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
8 L1	Male Wc Hand Dryer	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
9 L1	Water Heater Point Ladies Wc	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
10 L1	Circuit Not Found	---	---	---	---	---	---	---	---	---	---	---	---	
11 L1	Female Wc Hand Dryer	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
12 L1	Lights - Registrars/Stairwell/Lobby/Door Entry	A	100	---	1.5	1.0	0.4	3871	4	10	4	N/A	---	

ADDITIONAL COMMENTS													

SCHEDULE DETAILS			
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX	Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ
Location of Board:	Main Building	Supplied From:	Origin
Overcurrent Device:		Rating:	A
RCD Device:		RCD Rating:	mA
		Nominal Voltage:	230 V
		RCD No of Poles:	

CIRCUIT DETAILS													
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	Max disconnect time permitted by BS7671 s	BS(EN)	Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 $\Omega$
1 L2	Lights - First Floor Offices/Staff Rm/Store & Corridor	A	100	24	1.5	1.0	0.4	3871	4	10	4	N/A	---
2 L2	Sockets - F/F Offices/Staff Rm/Store Rm/Corridor	A	C	8	2.5	1.5	0.4	3871	2	32	6	N/A	1.03
	Way Not Available	---	---	---	---	---	---	---	---	---	---	---	---
3 L2	Computer Sockets F/F Offices/Staff room	A	C	6	2.5	1.5	0.4	3871	2	32	6	N/A	1.03
	Way Not Available	---	---	---	---	---	---	---	---	---	---	---	---
4 L2	Water Heater/ Door Entry	A	C	2	2.5	1.5	0.4	3871	2	15	6	N/A	2.19
5 L2	Sockets - Atrium Landing Offices	A	C	9	2.5	1.5	0.4	3871	2	32	6	N/A	1.03
6 L2	Lights - Atrium Landing Offices	A	100	13	1.5	1.0	0.4	3871	4	10	4	N/A	---
7 L2	Sockets - Atrium Landing Offices	A	C	12	2.5	1.5	0.4	3871	2	32	6	N/A	1.03

ADDITIONAL COMMENTS

SCHEDULE DETAILS							
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ		
Location of Board:	Corridor		Supplied From:	Origin		Nominal Voltage:	230 V
Overcurrent Device:			Rating:	A			
RCD Device:			RCD Rating:	mA		RCD No of Poles:	

CIRCUIT DETAILS														
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	BS(EN)		Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω	
1 L1	Hand Dryer - Wc 16	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
1 L2	Hand Dryer - Wc 17	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
1 L3	Spur - Disabled Wc	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
2L1	Spur - Wc 16	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
2 L2	Hand Dryer - Disabled Wc	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
2 L3	Water Heater - Disabled Wc	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
3L1	Sockets - Activity Room	A	C	4	2.5	1.5	0.4	60898	C	32	10	N/A	0.72	
3 L2	Fan Coil Unit - Reception	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
3 L3	Kitchen Fridge Isolator	A	C	1	6	2.5	0.4	60898	C	32	10	N/A	0.72	
4L1	Fan Coil Units - Activity/Meeting/Disbaled Wc	A	C	3	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
4 L2	Sockets - Reception Desk	A	C	6	2.5	1.5	0.4	60898	C	32	10	N/A	0.72	
4 L3	Sockets - kitchen and lobby	A	C	3	2.5	1.5	0.4	60898	C	32	10	N/A	0.72	
5L1	Disbale Wc Call System	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
5 L2	Sockets - Offices 8/10/11	A	C	11	2.5	1.5	0.4	60898	C	32	10	N/A	0.72	
5 L3	Dishwasher Supply	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
6L1	Fan Coil Units - Atrium Landing Offices	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
6 L2	Fan Coil Units - HFT Offices	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
6 L3	Kitchen Water Heater	A	C	1	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
7L1	Fan Coil Units - Atrium Landing Offices	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
7 L2	Fan Coil Units - HFT Offices	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
7 L3	Fan Coil Units - Offices 8/9	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
8L1	Floor Sockets + Photocopier - Room 20	A	C	5	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
8 L2	Fan Coil Units - First Floor Atrium	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
8 L3	Lights - Toilets	A	C	7	1.5	1.0	0.4	60898	B	10	10	N/A	4.60	

ADDITIONAL COMMENTS													

SCHEDULE DETAILS						
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ	
Location of Board:	Corridor	Supplied From:	Origin	Nominal Voltage:	230 V	
Overcurrent Device:		Rating:	A	RCD No of Poles:		
RCD Device:		RCD Rating:	mA			

CIRCUIT DETAILS														
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	BS(EN)		Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω	
9L1	Fan Coil Units - Offices 10/11/8	A	C	3	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
9 L2	Fan Coil Units - Council Chambers	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
9 L3	FAn Coil Units - Reception Area	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
10L1	Door Entry System Lobby 15	A	C	1	1.0	1.0	0.4	60898	B	6	10	N/A	7.67	
10 L2	Fan Coil Units - Council Chambers	A	C	2	2.5	1.5	0.4	60898	B	16	10	N/A	2.87	
10 L3	Unknown Circuit	A	C	---	1.5	1.0	0.4	60898	B	10	10	N/A	4.60	
11 TP	Condensor Unit No.2	F	C	1	6	40	0.4	60898	B	32	10	N/A	1.44	
12 TP	Condensor Unit No. 1	F	C	1	6	40	0.4	60898	B	32	10	N/A	1.44	
13 TP	Condensor Unit No. 4	F	C	1	6	40	0.4	60898	B	32	10	N/A	1.44	
14 TP	Condensor Unit No. 3	F	C	1	6	40	0.4	60898	B	32	10	N/A	1.44	
15 TP	Condensor Unit No. 5	F	C	1	6	40	5	60898	B	40	10	N/A	1.15	
16L1	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
16 L2	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
16 L3	Timeclock Supply	A	C	1	1.5	1.0	0.4	60898	B	6	10	N/A	7.67	
17 TP	Lift Supply	F	C	1	6	40	0.4	60898	B	32	10	N/A	1.44	
18 TP	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
19L1	Lights - Boiler Room	A	C	2	1.5	1.0	0.4	61009	C	10	---	30	2.30	
19 L2	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
19 L3	Socket - Safe Room	A	C	1	2.5	1.5	0.4	61009	B	20	10	30	2.30	
20 TP	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
21 TP	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
22 TP	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
23 TP	Spare	---	---	---	---	---	---	---	---	---	---	---	---	
24 TP	Spare	---	---	---	---	---	---	---	---	---	---	---	---	

ADDITIONAL COMMENTS													

SCHEDULE DETAILS					
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ
Location of Board:	Roberts & Lloyd		Supplied From:	MCCB Panel 1 - 1 L3	
Overcurrent Device:			Rating:	A	
RCD Device:			RCD Rating:	mA	
			Nominal Voltage:	230 V	
			RCD No of Poles:		

CIRCUIT DETAILS														
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	BS(EN)		Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω	
1 L1	Sockets - Ground Floor Atrium Office	A	C	13	2.5	1.5	0.4	60898	B	32	10	N/A	1.44	
2 L1	Spare													
3 L1	Spare													
4 L1	Lights - Ground Floor Antrium Office	A	C	17	1.5	1.0	0.4	60898	C	6	10	N/A	3.83	
5 L1	Door Release System	A	C	1	1.5	1.0	0.4	60898	C	6	10	N/A	3.83	
6 L1	Spare													
7 L1	Spare													
8 L1	Spare													
9 L1	Spare													
10 L1	Spare													
11 L1	Spare													
12 L1	Spare													
13														

ADDITIONAL COMMENTS



D.B. Roberts & Lloyd No. 2 CIRCUIT DETAILS

SCHEDULE DETAILS							
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ		
Location of Board:	Roberts & Lloyd		Supplied From:	MCCB Panel 1 - 1 L3		Nominal Voltage:	230 V
Overcurrent Device:			Rating:	A			
RCD Device:			RCD Rating:	mA		RCD No of Poles:	

CIRCUIT DETAILS													
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Overcurrent protective devices	RCD	Maximum Zs permitted by BS7671			
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	Max disconnect time permitted by BS7671 s				BS(EN)	Type No	Rating A
1 L1	Lights - F/F Offices, WC & Stairwell	A	C	15	1.5	1.0	0.4	3871	4	10	6	N/A	
2 L1	Extraction Fans	A	C	1	1.5	1.0	0.4	60898	B	2	6	N/A	N/A
3 L1	Lights - S/F Offices	A	C	13	1.5	1.0	0.4	3871	4	10	6	N/A	
4 L1	Sockets - F/F & S/F Offices	A	C	12	2.5	1.5	0.4	3871	2	32	6	N/A	1.03
5 L1	Spare												
6 L1	Sockets - kitchen.	A	C	2	2.5	1.5	0.4	3871	2	32	6	N/A	1.03
7 L1	Sockets - Computers	A	C	5	2.5	1.5	0.4	3871	2	32	6	N/A	1.03
8 L1	Spare												
9 L1	Spare												
10 L1	Water Heater - Toilets	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19
11 L1	Water Heater - Kitchen	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19
12 L1	Hand Dryer - Gents Wc	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19
13 L1	Hand Dryer - Ladies Wc	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19
14 L1	Air Conditioning Unit on Roof 1	A	C	1	4	1.5	0.4	3871	2	32	6	N/A	1.03
15 L1	Air Conditioning Unit on Roof 2	A	C	1	4	1.5	0.4	3871	2	32	6	N/A	1.03

ADDITIONAL COMMENTS													

SCHEDULE DETAILS							
Client Address:	Cotswold District Council, Trinity Road, Cirencester, Glos, GL7 1PX			Installation Address:	Moreton-in-Marsh Tourist Information Centre, Moreton Area Centre, High Street, Moreton-in-Marsh, GL56 0AZ		
Location of Board:	Ground Floor Offices		Supplied From:	MCCB Panel 1 - 1 L3		Nominal Voltage:	230 V
Overcurrent Device:			Rating:	A			
RCD Device:			RCD Rating:	mA		RCD No of Poles:	

CIRCUIT DETAILS														
Circuit number	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa			Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>	BS(EN)		Type No	Rating A	Short-circuit Capacity kA	Operating current mA	Maximum Zs permitted by BS7671 Ω	
1 L1	Lights - Ground Floor Offices	A	C	4	1.5	1.0	0.4	3871	4	10	6	N/A		
2 L1	Lights - Ground Floor Reception	A	C	12	1.5	1.0	0.4	3871	4	10	6	N/A		
3 L1	Sockets - Reception/Offices	A	C	7	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
4 L1	Sockets - Back Offices Ground Floor	A	C	8	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
5 L1	Sockets - Ground Floor Reception/ Offices	A	C	9	2.5	1.5	0.4	3871	2	32	6	N/A	1.03	
6 L1	Water Heater - Ladies Wc	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
7 L1	Fused Spur In Cupboard	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
8 L1	Hand Dryer - Ladies Wc	A	C	1	2.5	1.5	0.4	3871	2	15	6	N/A	2.19	
9 L1	Auto Door & Heater in Entrance	A	C	2	4	1.5	0.4	3871	2	15	6	N/A	2.19	
10 L1	Large Hanging Lights in Reception	A	C	4	1.5	1.0	0.4	60898	B	10	6	N/A	4.60	
11 L1	Reception Spot Lights	A	C	8	1.5	1.0	0.4	60898	B	10	6	N/A	4.60	
12 L1	Atrium Fans	A	C	3	1.5	1.0	0.4	60898	B	6	6	N/A	7.67	

**ADDITIONAL COMMENTS**